


TOSHA
25 MOST CITED PUBLIC SECTOR STANDARDS
 January 1, 2007–December 31, 2007



Rank	#Cited	Standard	Hazard Description
1	71	1910.303(g)(1)(i)	Workspace Maintained Less Than 30 inches in Front of Electric Equipment.
2	64	1910.157(e)(2)	No Monthly Visual Inspection of Fire Extinguishers
3	62	1910.305(b)(1)	Conductors Unprotected and Openings Not Closed
4	58	1910.215(b)(9)	Missing Tongue Guard on Grinder
5	54	1910.305(b)(2)	No Covers on Pull Boxes, Junction Boxes, and Fittings
6	50	1910.157(c)(1)	Portable Fire Extinguishers Not Accessible
7	49	1910.1200(e)(1)	No Written Hazard Communication Program
8	49	1910.304(f)(4)	No Permanent or Continuous Electrical Path to Ground
9	37	1910.215(a)(4)	Missing Work Rest on Grinder
10	36	1910.157(e)(3)	No Annual Maintenance Check of Portable Fire Extinguishers
11	34	1910.303(f)	Electrical Disconnecting Means Not Legibly Marked
12	31	1910.305(a)(4)(v)	Electrical Wires Within 7 Feet of Floor Not Protected
13	30	1910.303(b)(2)	Electrical Equipment Not Installed and Used in Accordance with Listing or Labeling
14	28	1910.22(a)(1)	Poor Housekeeping
15	25	0800-1-9-.06(2)	No Non-containerized Chemical Warnings
16	24	1910.1200(g)(1)	No MSDS for Hazardous Chemicals
17	22	1910.305(j)(2)(ii)	Unsuitable Electric Receptacle in Damp or Wet Location
18	21	1910.1030(c)(1)(i)	No Written Exposure Control Plan
19	21	1910.22(d)(1)	No Sign Indicating Approved Load Level (Overhead Storage)
20	20	1910.305(g)(2)(iii)	Strain Relief Not Provided on Flexible Cords
21	19	1910.304(f)(5)(v)	Equipment Connected by Cord and Plug Not Grounded
22	19	1910.212(b)	Machinery Not Securely Anchored
23	17	1910.1200(h)(1)	Inadequate Training on Hazardous Chemicals
24	17	1910.303(g)(2)(i)	Electrical Equipment 50-volts or More Not Guarded Against Accidental Contact
25	17	1910.151(c)	No Emergency Eye Wash and/or Shower